

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001
Facility: Huntsville Wastewater Treatment Facility
Address: 30187 Madison Hwy 23
City: Huntsville State: AR Zip: 72740
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>11-30-18</u>	<u>Nitrite + Nitrate</u>		<u>21.6 mg/l</u>	<u>15 mg/l</u>

We feel this problem was due to:

A continuing problem due to inability to properly mix our aeration system and our industry giving us too little food.

We plan on correcting the problem in this manner:

Continue with the mixer project and communication with our industry and sending us more loading

Time estimated that it will take to correct problem:

July 2019

Sincerely,

Larry D. Barrett

Submitted By:

6/13/2019
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)