

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001
 Facility: Huntsville Wastewater Treatment Facility
 Address: 30187 Madison Hwy 23
 City: Huntsville State: AR Zip: 72740
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11-1-18 thru 11-30-18 *	Nitrite + Nitrate	193.4 lbs/day	16.8 mg/l	166.8 lbs/day 10 mg/l
11-1-18 thru 11-30-18 *	Nitrite + Nitrate		18.4 mg/l	15 mg/l
11-12-18	Nitrite + Nitrate			

We feel this problem was due to:

Problem was due to Industry doing a better job at their facility pretreatment

* monthly AVE

We plan on correcting the problem in this manner:

Still in the bid process of obtaining mixers for Nitrate removal and are trying to add more food to our system through communitization with our Industry

Time estimated that it will take to correct problem:

July 2019

Sincerely,

Larry D. Barnett

Submitted By:

6/13/2019
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)