

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001
 Facility: Huntsville Wastewater Treatment Facility
 Address: 30187 Madison Hwy 23
 City: Huntsville State: AR Zip: 72740
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3-29-18	Fecal Coliform		8000 col/100ml	2000 cf/100ml.

We feel this problem was due to:

Cross contamination either at time of sampling or at the contract lab. The weeks before and after the sample on the 29th were less than 4 with no changes to our system.

We plan on correcting the problem in this manner:

Ensuring that there is proper sampling and analysis on this test.

Time estimated that it will take to correct problem:

Completed

Sincerely,

Larry D. Sanitt

Submitted By:

6/13/2019
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)