

ADEQ

ARKANSAS
Department of Environmental Quality

January 4, 2016

Kevin Hatfield
Mayor, City of Huntsville
112 West War Eagle
Huntsville, AR 72740

RE: NPDES Permit Number AR0022004, AFIN 44-00018
NPDES Permit Effluent Violations

Dear Honorable Hatfield,


The Department recently performed a file review of the above referenced permit. The review revealed the following effluent violations:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	Violation Code	% Vio	Parameter Code
10/31/2015	001-A	Nitrite + Nitrate total [as N], MO AVG, mg/L	10	13.2	E90	32%	00630-1-0
10/31/2015	001-A	Nitrite + Nitrate total [as N], 7 DA AVG, mg/L	15	17.9	E90	19%	00630-1-0

Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0630 or e-mail at allen-daniel@adeq.state.ar.us.

Sincerely,



Leslie Allen-Daniel
Enforcement Analyst
Water Division, Enforcement Branch